

**Government of Bihar**  
**Public Health Engineering Department**  
 Water Quality Testing Report  
 Sample Given By Principal

Month: July- 2024

District Name: Purnea			Division Name: P.H.Division,Purnea			Parameters										Remarks
SL. No.	Block	Panchyat	Village/Habitation	Location of source	Type of source	pH	Turb.	EC	TDS	TH	Cl	Alka.	Fe	NO <sub>3</sub>	Total Coli	
1	Jalalgarh	Dansar	Kankhodiya	INDIAN PUBLIC SCHOOL.	H.P	7.1	3.0	650	326	235.2	50.65	176.4	0.9	BDL	NEGATIVE	जल पम्प का सग्रह सग्रह लाभार्थी के द्वारा किया गया है। जल शुद्धता की गारंटी जल सग्रह करने के तरीके एवं सग्रहकर्ता के उपर निर्भर करता है।
2	Jalalgarh	Dansar	Kankhodiya	INDIAN PUBLIC SCHOOL	Tap Water	7	2.0	547	271	196	41.2	156.8	0.40	BDL	NEGATIVE	
Desirable Limit*						6.5-8.5	5.0	-	500	300	250	200	1.0	45	NEGATIVE	
Permissible Limit* in absence of alternate source						NR	10.0	-	2000	600	1000	600	NR	NR	NEGATIVE	

*Sasha*  
 30/7/24  
 Chemist  
 P.H. Division, Purnea

*[Signature]*  
 30/7/24  
 A.E.  
 P.H. Sub Division, Purnea

*[Signature]*  
 30.07.24  
 Executive Engineer  
 P.H. Division, Purnea

*[Signature]*  
 Principal  
 Indian Public School  
 Sarsauni Road Jalalgarh  
 Purnea-854 327

*[Signature]*  
 MANAGER  
 INDIAN PUBLIC SCHOOL  
 SARSOONI ROAD JALALGARH,  
 PURNEA-854326